



2829 Transworld Dr.  
Stockton, CA 95206

Mailing Address: P.O. Box 213030, Stockton CA 95213  
Telephone: (209) 468-5940 Fax: (209) 468-9000

September 3, 2008

To: The Parents of Students Attending Venture Academy and Career and Technical High School

Re: Public Notification Requirement of California Health and Safety Code §42301.6

Project Number: N-1082809

Project Description: Installation of a new emergency-standby engine powering an electrical generator

Dear Parents:

The San Joaquin Valley Air Pollution Control District (Air District) intends to issue an Authority to Construct permit to San Joaquin County Office of Education for the installation of a new diesel-fired emergency standby internal combustion (IC) engine location at 2901 Arch-Airport Road in Stockton, CA.

Section §42301.6 of the California Health & Safety Code states that if a new or modified source, which emits hazardous air emissions, is located within 1,000 feet of the outer boundary of any Kindergarten through Grade 12 school site, the Air District must prepare and distribute a public notice. The notice must be distributed to each student enrolled in any Kindergarten through Grade 12 school within a one-quarter mile radius of the proposed source and to each address within a radius of 1,000 feet of the proposed source.

The equipment to be operated at this location consists of the following:

**538 BHP JOHN DEERE MODEL 6135H TIER 3 DIESEL-FIRED EMERGENCY-STANDBY IC ENGINE  
POWERING AN ELECTRICAL GENERATOR**

The Air District has determined that, as proposed, the installation will comply with all Air District regulations. The Air District's analysis of the proposal has determined that the emissions from operation of this equipment will not pose a significant health risk to the school children or to the surrounding public.

In addition, the Health and Safety Code requires that the Air District receive and address any public comments. Should you have any questions or comments, please submit them in writing within 30 days of the date of this note to the following:

**SAN JOAQUIN VALLEY APCD  
ATTN: Brian Clerico  
1990 E. Gettysburg Ave.  
Fresno, CA 93726-0244**

You may also contact Brian Clerico at (559) 230-5892.